地下水、浸出水、放流水及び防災調節池放出水の放射能濃度（Cs-134,Cs-137）（令和4年度）

（単位:Bq/L）

調査地点	調査項目	令和4年度																											
		4月				5月				6月					7月					8月					9月				
		—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	27日	—
1 C-1 地下水(未処理)	Cs-134																												
	Cs-137																												
2 C-1 地下水(ろ過)※	Cs-134																												
	Cs-137																												
3 C-2 地下水(未処理)	Cs-134																											ND	
	Cs-137																											ND	
4 C-2 地下水(ろ過)※	Cs-134																											ND	
	Cs-137																											ND	
5 Sn-1 浸出水(未処理)	Cs-134																											ND	
	Cs-137																											ND	
6 Sn-1 浸出水(ろ過)※	Cs-134																											ND	
	Cs-137																											ND	
7 Sh-1 放流水(未処理)	Cs-134																											ND	
	Cs-137																											ND	
8 Sh-1 放流水(ろ過)※	Cs-134																											ND	
	Cs-137																											ND	
9 B-1 防災調節池放出水(未処理)	Cs-134																											ND	
	Cs-137																											1.0	
10 B-1 防災調節池放出水(ろ過)※	Cs-134																											ND	
	Cs-137																											ND	

調査地点	調査項目	10月					11月					12月					1月						2月					3月					
		—	—	24日	25日	—	—	—	—	—	25日	—	—	15日	—	—	—	—	—	19日	20日	—	—	—	—	20日	21日	—	—	16日	—	—	—
1 C-1 地下水(未処理)	Cs-134													ND							ND						ND			ND			
	Cs-137													ND							ND						ND			ND			
2 C-1 地下水(ろ過)※	Cs-134													ND							ND						ND			ND			
	Cs-137													ND							ND						ND			ND			
3 C-2 地下水(未処理)	Cs-134			ND							ND			ND						ND							ND			ND			
	Cs-137			ND							ND			1.0						ND							ND			ND			
4 C-2 地下水(ろ過)※	Cs-134			ND							ND			ND						ND							ND			ND			
	Cs-137			ND							ND			ND						ND							ND			ND			
5 Sn-1 浸出水(未処理)	Cs-134				ND						ND			ND						ND						ND				ND			
	Cs-137				ND						1.7			ND						2.4						ND				ND			
6 Sn-1 浸出水(ろ過)※	Cs-134				ND						ND			ND						ND						ND				ND			
	Cs-137				ND						ND			ND						ND						ND				ND			
7 Sh-1 放流水(未処理)	Cs-134				ND						ND			ND						ND						ND				ND			
	Cs-137				ND						ND			ND						ND						ND				ND			
8 Sh-1 放流水(ろ過)※	Cs-134				ND						ND			ND						ND						ND				ND			
	Cs-137				ND						ND			ND						ND						ND				ND			
9 B-1 防災調節池放出水(未処理)	Cs-134										ND									ND										ND			
	Cs-137										ND									ND										ND			
10 B-1 防災調節池放出水(ろ過)※	Cs-134										ND									ND										ND			
	Cs-137										ND									ND										ND			

（注）1)【ND】は、検出下限値(1Bq/L)未満であることを示す。

2)浸出水は、11月度定期モニタリング調査から浸出水処理施設の原水槽から採水。

地下水、浸出水、放流水及び防災調節池放出水の放射能濃度（Cs-134,Cs-137）（令和5年度）

（単位:Bq/L）

調査地点	調査項目	令和5年度																											
		4月				5月				6月					7月					8月					9月				
		—	—	20日	21日	—	—	18日	—	8日	15日	19日	20日	29日	6日	13日	20日	21日	27日	3日	10日	17日	24日	31日	7日	14日	21日	22日	28日
1 C-1 地下水(未処理)	Cs-134				ND			ND					ND					ND					ND					ND	
	Cs-137				ND			ND					ND					ND					ND					ND	
2 C-1 地下水(ろ過)※	Cs-134				ND			ND					ND					ND					ND					ND	
	Cs-137				ND			ND					ND					ND					ND					ND	
3 C-2 地下水(未処理)	Cs-134				ND			ND					ND					ND					ND					ND	
	Cs-137				ND			ND					ND					ND					ND					ND	
4 C-2 地下水(ろ過)※	Cs-134				ND			ND					ND					ND					ND					ND	
	Cs-137				ND			ND					ND					ND					ND					ND	
5 Sn-1 浸出水(未処理)	Cs-134			ND				ND		ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
	Cs-137			ND				ND		ND	ND	ND		ND	ND	1.3	ND		ND	ND	ND	ND	ND	ND	ND	1.1	ND		ND
6 Sn-1 浸出水(ろ過)※	Cs-134			ND				ND		ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
	Cs-137			ND				ND		ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
7 Sh-1 放流水(未処理)	Cs-134			ND				ND		ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
	Cs-137			ND				ND		ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
8 Sh-1 放流水(ろ過)※	Cs-134			ND				ND		ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
	Cs-137			ND				ND		ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
9 B-1 防災調節池放出水(未処理)	Cs-134							ND															ND						
	Cs-137							ND															ND						
10 B-1 防災調節池放出水(ろ過)※	Cs-134							ND															ND						
	Cs-137							ND															ND						

調査地点	調査項目	10月					11月						12月					1月					2月						3月				
		5日	12日	19日	20日	26日	2日	9日	16日	17日	23日	30日	7日	14日	21日	22日	28日	4日	11日	18日	19日	25日	1日	8日	15日	16日	22日	29日	7日	14日	21日	22日	28日
1 C-1 地下水(未処理)	Cs-134				ND					ND						ND					ND					ND						ND	
	Cs-137				ND					ND						ND					ND					ND						ND	
2 C-1 地下水(ろ過)※	Cs-134				ND					ND						ND					ND					ND						ND	
	Cs-137				ND					ND						ND					ND					ND						ND	
3 C-2 地下水(未処理)	Cs-134				ND					ND						ND					ND					ND						ND	
	Cs-137				ND					ND						ND					ND					ND						ND	
4 C-2 地下水(ろ過)※	Cs-134				ND					ND						ND					ND					ND						ND	
	Cs-137				ND					ND						ND					ND					ND						ND	
5 Sn-1 浸出水(未処理)	Cs-134	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
6 Sn-1 浸出水(ろ過)※	Cs-134	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
7 Sh-1 放流水(未処理)	Cs-134	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
8 Sh-1 放流水(ろ過)※	Cs-134	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND
9 B-1 防災調節池放出水(未処理)	Cs-134								ND																ND								
	Cs-137								ND																ND								
10 B-1 防災調節池放出水(ろ過)※	Cs-134								ND																ND								
	Cs-137								ND																ND								

（注）【ND】は、検出下限値(1Bq/L)未満であることを示す。

地下水、浸出水、放流水及び防災調節池放出水の放射能濃度（Cs-134,Cs-137）（令和6年度）

（単位:Bq/L）

令和6年度

調査地点	調査項目	4月					5月						6月					7月					8月						9月				
		4日	11日	18日	19日	25日	2日	9日	16日	23日	24日	30日	6日	13日	20日	21日	27日	4日	11日	18日	19日	25日	1日	8日	15日	22日	23日	29日	5日	12日	19日	20日	26日
1 C-1 地下水(未処理)	Cs-134				ND						ND					ND					ND						ND					ND	
	Cs-137				ND						ND					ND					ND						ND					ND	
2 C-1 地下水(ろ過)※	Cs-134				ND						ND					ND					ND						ND					ND	
	Cs-137				ND						ND					ND					ND						ND					ND	
3 C-2 地下水(未処理)	Cs-134				ND						ND					ND					ND						ND					ND	
	Cs-137				ND						ND					ND					ND						ND					ND	
4 C-2 地下水(ろ過)※	Cs-134				ND						ND					ND					ND						ND					ND	
	Cs-137				ND						ND					ND					ND						ND					ND	
5 Sn-1 浸出水(未処理)	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
6 Sn-1 浸出水(ろ過)※	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
7 Sh-1 放流水(未処理)	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
8 Sh-1 放流水(ろ過)※	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND
9 B-1 防災調節池放出水(未処理)	Cs-134									ND																ND							
	Cs-137									ND																ND							
10 B-1 防災調節池放出水(ろ過)※	Cs-134									ND																ND							
	Cs-137									ND																ND							

調査地点	調査項目	10月						11月					12月						1月						2月					3月					
		3日	10日	17日	18日	24日	31日	7日	14日	21日	22日	28日	5日	12日	19日	20日	26日	30日	6日	9日	16日	23日	24日	30日	6日	13日	20日	25日	26日	6日	13日	17日	18日	27日	27日
1 C-1 地下水(未処理)	Cs-134				ND						ND					ND							ND						ND				ND		
	Cs-137				ND						ND					ND							ND						ND				ND		
2 C-1 地下水(ろ過)※	Cs-134				ND						ND					ND							ND						ND				ND		
	Cs-137				ND						ND					ND							ND						ND				ND		
3 C-2 地下水(未処理)	Cs-134				ND						ND					ND							ND						ND				ND		
	Cs-137				ND						ND					ND							ND						ND				ND		
4 C-2 地下水(ろ過)※	Cs-134				ND						ND					ND							ND						ND				ND		
	Cs-137				ND						ND					ND							ND						ND				ND		
5 Sn-1 浸出水(未処理)	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
6 Sn-1 浸出水(ろ過)※	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
7 Sh-1 放流水(未処理)	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
8 Sh-1 放流水(ろ過)※	Cs-134	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
	Cs-137	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	
9 B-1 防災調節池放出水(未処理)	Cs-134									ND																		ND							
	Cs-137									ND																		ND							
10 B-1 防災調節池放出水(ろ過)※	Cs-134									ND																		ND							
	Cs-137									ND																		ND							

（注）【ND】は、検出下限値(1Bq/L)未満であることを示す。

地下水、浸出水、放流水及び防災調節池放出水の放射能濃度（Cs-134,Cs-137）（令和7年度）

（単位:Bq/L）

令和7年度

調査地点	調査項目	4月					5月						6月					7月						8月					9月				
		3日	10日	11日	17日	24日	1日	8日	15日	16日	22日	29日	5日	12日	13日	19日	26日	3日	10日	17日	18日	24日	31日	7日	8日	14日	21日	28日	4日	11日	17日	18日	25日
1 C-1 地下水(未処理)	Cs-134			ND						ND					ND						ND				ND							ND	
	Cs-137			ND						ND					ND						ND				ND							ND	
2 C-1 地下水(ろ過)※	Cs-134			ND						ND					ND						ND				ND							ND	
	Cs-137			ND						ND					ND						ND				ND							ND	
3 C-2 地下水(未処理)	Cs-134			ND						ND					ND						ND				ND							ND	
	Cs-137			ND						ND					ND						ND				ND							ND	
4 C-2 地下水(ろ過)※	Cs-134			ND						ND					ND						ND				ND							ND	
	Cs-137			ND						ND					ND						ND				ND							ND	
5 Sn-1 浸出水(未処理)	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
6 Sn-1 浸出水(ろ過)※	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
7 Sh-1 放流水(未処理)	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
8 Sh-1 放流水(ろ過)※	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND		ND
9 B-1 防災調節池放出水(未処理)	Cs-134								ND																		ND						
	Cs-137								ND																		ND						
10 B-1 防災調節池放出水(ろ過)※	Cs-134								ND																		ND						
	Cs-137								ND																		ND						

調査地点	調査項目	10月						11月					12月						1月						2月					3月					
		2日	9日	10日	16日	23日	30日	6日	13日	14日	20日	27日	4日	5日	11日	18日	25日	29日	5日	8日	15日	16日	22日	29日	5日	12日	13日	19日	26日	5日	6日	12日	19日	26日	31日
1 C-1 地下水(未処理)	Cs-134			ND						ND				ND								ND					ND				ND				
	Cs-137			ND						ND				ND								ND					ND				ND				
2 C-1 地下水(ろ過)※	Cs-134			ND						ND				ND								ND					ND				ND				
	Cs-137			ND						ND				ND								ND					ND				ND				
3 C-2 地下水(未処理)	Cs-134			ND						ND				ND								ND					ND				ND				
	Cs-137			ND						ND				ND								ND					ND				ND				
4 C-2 地下水(ろ過)※	Cs-134			ND						ND				ND								ND					ND				ND				
	Cs-137			ND						ND				ND								ND					ND				ND				
5 Sn-1 浸出水(未処理)	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
6 Sn-1 浸出水(ろ過)※	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
7 Sh-1 放流水(未処理)	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
8 Sh-1 放流水(ろ過)※	Cs-134	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
	Cs-137	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND	ND		ND	ND	ND	ND
9 B-1 防災調節池放出水(未処理)	Cs-134								ND																	ND									
	Cs-137								ND																	ND									
10 B-1 防災調節池放出水(ろ過)※	Cs-134								ND																	ND									
	Cs-137								ND																	ND									

（注）【ND】は、検出下限値(1Bq/L)未満であることを示す。

地下水、浸出水、放流水及び防災調節池放出水の放射能濃度（Cs-134,Cs-137）（令和8年度）


（単位:Bq/L）

調査地点	調査項目	令和8年度 4月 7日	14日	15日	21日	28日	5月 5日	13日	14日	19日	26日	6月 2日	9日	10日	16日	23日	30日	7月 7日	14日	15日	21日	28日	8月 4日	11日	19日	20日	25日	9月	10月	11月	12月	1月	2月	3月
1 C-1 地下水(未処理)	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
2 C-1 地下水(ろ過)※	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
3 C-9 地下水(未処理)	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
4 C-9 地下水(ろ過)※	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
3 C-10 地下水(未処理)	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
4 C-10 地下水(ろ過)※	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
3 地下水集水管(東)(未処理)	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
4 地下水集水管(東)(ろ過)※	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
3 地下水集水管(西)(未処理)	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
4 地下水集水管(西)(ろ過)※	Cs-134			ND				ND						ND						ND					ND								
	Cs-137			ND				ND						ND						ND					ND								
5 Sn-1 浸出水(未処理)	Cs-134	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
	Cs-137	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
6 Sn-1 浸出水(ろ過)※	Cs-134	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
	Cs-137	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
7 Sh-1 放流水(未処理)	Cs-134	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
	Cs-137	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
8 Sh-1 放流水(ろ過)※	Cs-134	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
	Cs-137	ND	ND		ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND	ND		ND	ND	ND	ND		ND	ND						
9 B-1 防災調節池放出水(未処理)	Cs-134								ND																	ND								
	Cs-137								ND																	ND								
10 B-1 防災調節池放出水(ろ過)※	Cs-134								ND																	ND								
	Cs-137								ND																	ND								

（注）【ND】は、検出下限値（1Bq/L）未満であることを示す。


※令和８年３月まで

地下水水質測定位置図




※令和８年４月～


地下水水質測定位置図



浸出水水質測定地図



放流水水質測定位置図



防災調節池放出水水質測定地図

