

浸出水原水、処理水、放流水及び地下水の放射能濃度 (Cs-134,Cs-137) (平成29年度)

| 実施年度         | 平成29年度 |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |     |    |     |     |     |    |     |     |     |    |     |       |       |       |       |       |       |       |       |     |     |
|--------------|--------|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-------|-------|-------|-------|-------|-------|-------|-------|-----|-----|
|              | 4月     |    |     |     | 5月  |    |    |     |     | 6月  |    |     |     | 7月  |    |     |     | 8月  |    |    |     |     | 9月  |    |     |     | 10月 |    |     |     | 11月 |     |    |     | 12月 |     |    |     | 1月  |     |    | 2月  |       |       |       | 3月    |       |       |       |       |     |     |
|              | 調査日    | 4日 | 12日 | 18日 | 25日 | 2日 | 9日 | 16日 | 23日 | 30日 | 6日 | 13日 | 20日 | 27日 | 4日 | 12日 | 19日 | 25日 | 1日 | 9日 | 17日 | 22日 | 29日 | 5日 | 13日 | 20日 | 26日 | 3日 | 12日 | 17日 | 24日 | 31日 | 6日 | 15日 | 22日 | 29日 | 5日 | 13日 | 18日 | 26日 | 5日 | 10日 | 17日   | 25日   | 30日   | 7日    | 15日   | 21日   | 27日   | 6日    | 14日 | 23日 |
| 1 浸出水原水(未処理) | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | 2.87* | 3.54* | 2.17* | 2.38* | 1.96* | ND    | ND    | 1.20* | ND  | ND  |
| 2 浸出水原水(ろ過)* | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | 2.47* | 3.27* | 2.17* | 2.21* | 1.83* | ND    | ND    | ND    | ND  | ND  |
| 3 処理水(未処理)   | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND    | ND    | 1.50* | 1.29* | 1.38* | 1.80* | 1.68* | 1.13* | ND  | ND  |
| 4 処理水(ろ過)*   | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND    | ND    | ND    | 1.10* | ND    | 1.74* | 1.37* | 1.03* | ND  | ND  |
| 5 放流水(未処理)   |        | ND |     |     |     | ND |    |     |     | ND  |    |     |     | ND  |    |     |     | ND  |    |    |     | ND  |     |    |     | ND  |     |    |     | ND  |     |     |    | ND  |     |     |    | ND  |     |     |    |     |       |       |       |       |       |       | ND    |       |     |     |
| 6 放流水(ろ過)*   |        | ND |     |     |     | ND |    |     |     | ND  |    |     |     | ND  |    |     |     | ND  |    |    |     | ND  |     |    |     | ND  |     |    |     | ND  |     |     |    | ND  |     |     |    | ND  |     |     |    |     |       |       |       |       |       |       |       | ND    |     |     |
| 7 地下水(未処理)   |        | ND |     |     |     | ND |    |     |     | ND  |    |     |     | ND  |    |     |     | ND  |    |    |     | ND  |     |    |     | ND  |     |    |     | ND  |     |     |    | ND  |     |     |    | ND  |     |     |    |     |       |       |       |       |       |       |       | ND    |     |     |
| 8 地下水(ろ過)*   |        | ND |     |     |     | ND |    |     |     | ND  |    |     |     | ND  |    |     |     | ND  |    |    |     | ND  |     |    |     | ND  |     |    |     | ND  |     |     |    | ND  |     |     |    | ND  |     |     |    |     |       |       |       |       |       |       |       | ND    |     |     |

- (注) 1) 単位: Bq/L  
 2) ※: 試料を孔径0.45 μmのメンブランフィルターでろ過した後の測定値を示す。  
 3) 地下水は地下水集水管排水を対象とした。  
 4) 【ND】は、Cs-134,Cs-137ともに検出下限値(1Bq/L)未満であることを示す。また、数値はCs-134及びCs-137の合計値を示す。  
 5) \*: 一部の浸出水原水、処理水から放射性セシウムが検出されたが、実態調査の結果、廃棄物由来ではないことが確認された。

浸出水原水、処理水、放流水及び地下水の放射能濃度 (Cs-134,Cs-137) (平成30年度)

| 実施年度         | 平成30年度 |       |     |     |     |    |     |     |     |     |    |     |     |     |    |     |     |     |    |     |     |     |     |    |     |     |     |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |     |    |     |     |     |    |     |     |     |    |    |    |  |    |  |  |  |  |    |  |
|--------------|--------|-------|-----|-----|-----|----|-----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|----|--|----|--|--|--|--|----|--|
|              | 4月     |       |     |     | 5月  |    |     |     |     | 6月  |    |     |     | 7月  |    |     |     | 8月  |    |     |     |     | 9月  |    |     |     | 10月 |    |     |     | 11月 |    |    |     | 12月 |     |    |     | 1月  |     |    | 2月  |     |     |     | 3月 |     |     |     |    |     |     |     |    |    |    |  |    |  |  |  |  |    |  |
|              | 調査日    | 5日    | 12日 | 19日 | 26日 | 2日 | 10日 | 17日 | 22日 | 31日 | 7日 | 13日 | 21日 | 28日 | 5日 | 12日 | 19日 | 26日 | 2日 | 10日 | 16日 | 23日 | 30日 | 6日 | 13日 | 20日 | 28日 | 4日 | 11日 | 18日 | 25日 | 1日 | 8日 | 15日 | 22日 | 29日 | 6日 | 13日 | 20日 | 27日 | 4日 | 10日 | 17日 | 24日 | 31日 | 7日 | 14日 | 21日 | 28日 | 8日 | 14日 | 20日 | 25日 |    |    |    |  |    |  |  |  |  |    |  |
| 1 浸出水原水(未処理) | ND     | 1.28* | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND |  |    |  |  |  |  |    |  |
| 2 浸出水原水(ろ過)* | ND     | 1.02* | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND |  |    |  |  |  |  |    |  |
| 3 処理水(未処理)   | ND     | ND    | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND |  |    |  |  |  |  |    |  |
| 4 処理水(ろ過)*   | ND     | ND    | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND |  |    |  |  |  |  |    |  |
| 5 放流水(未処理)   |        |       | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |     |     |     | ND  |    |     |     |     | ND |     |     |     |    | ND |     |     |     |    | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |    |    |  | ND |  |  |  |  | ND |  |
| 6 放流水(ろ過)*   |        |       | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |     |     |     | ND  |    |     |     |     | ND |     |     |     |    | ND |     |     |     |    | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |    |    |  | ND |  |  |  |  |    |  |
| 7 地下水(未処理)   |        |       | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |     |     |     | ND  |    |     |     |     | ND |     |     |     |    | ND |     |     |     |    | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |    |    |  |    |  |  |  |  |    |  |
| 8 地下水(ろ過)*   |        |       | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |     |     |     | ND  |    |     |     |     | ND |     |     |     |    | ND |     |     |     |    | ND  |     |     |    |     | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |    |    |  |    |  |  |  |  |    |  |

- (注) 1) 単位: Bq/L  
 2) ※: 試料を孔径0.45 μmのメンブランフィルターでろ過した後の測定値を示す。  
 3) 地下水は地下水集水管排水を対象とした。  
 4) 【ND】は、Cs-134,Cs-137ともに検出下限値(1Bq/L)未満であることを示す。また、数値はCs-134及びCs-137の合計値を示す。  
 5) \*: 一部の浸出水原水、処理水から放射性セシウムが検出されたが、実態調査の結果、廃棄物由来ではないことが確認された。

浸出水原水、処理水、放流水及び地下水の放射能濃度 (Cs-134,Cs-137) (平成31年度/令和元年度)

| 実施年度         | 平成31年度 |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     | 令和元年度 |     |    |    |     |     |     |    |     |     |     |    |     |     |     |     |    |     |     |     |    |     |     |     |     |    |     |     |     |    |     |     |     |    |     |     |     |    |    |    |    |    |    |    |
|--------------|--------|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-------|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|----|----|----|----|----|
|              | 4月     |    |     |     | 5月  |    |    |     |     | 6月  |    |     |     | 7月  |    |     |       | 8月  |    |    |     |     | 9月  |    |     |     | 10月 |    |     |     | 11月 |     |    |     | 12月 |     |    |     | 1月  |     |     | 2月 |     |     |     | 3月 |     |     |     |    |     |     |     |    |    |    |    |    |    |    |
|              | 調査日    | 4日 | 11日 | 18日 | 25日 | 2日 | 9日 | 16日 | 23日 | 30日 | 6日 | 13日 | 20日 | 27日 | 5日 | 11日 | 18日   | 25日 | 1日 | 8日 | 15日 | 22日 | 29日 | 5日 | 12日 | 19日 | 26日 | 3日 | 10日 | 17日 | 24日 | 31日 | 7日 | 14日 | 21日 | 28日 | 5日 | 12日 | 19日 | 26日 | 30日 | 9日 | 16日 | 23日 | 30日 | 6日 | 13日 | 20日 | 27日 | 5日 | 12日 | 19日 | 23日 |    |    |    |    |    |    |    |
| 1 浸出水原水(未処理) | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND    | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND | ND | ND | ND | ND |
| 2 浸出水原水(ろ過)* | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND    | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND | ND | ND | ND | ND |
| 3 処理水(未処理)   | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND    | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND | ND | ND | ND | ND |
| 4 処理水(ろ過)*   | ND     | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND    | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND | ND | ND | ND | ND |
| 5 放流水(未処理)   |        | ND |     |     |     |    |    | ND  |     |     |    |     | ND  |     |    |     |       | ND  |    |    |     |     | ND  |    |     |     |     | ND |     |     |     |     | ND |     |     |     |    | ND  |     |     |     |    | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |    |    |    | ND |    |    |
| 6 放流水(ろ過)*   |        | ND |     |     |     |    |    | ND  |     |     |    |     | ND  |     |    |     |       | ND  |    |    |     |     | ND  |    |     |     |     | ND |     |     |     |     | ND |     |     |     |    | ND  |     |     |     |    | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |    |    |    |    |    |    |
| 7 地下水(未処理)   |        | ND |     |     |     |    |    | ND  |     |     |    |     | ND  |     |    |     |       | ND  |    |    |     |     | ND  |    |     |     |     | ND |     |     |     |     | ND |     |     |     |    | ND  |     |     |     |    | ND  |     |     |    |     | ND  |     |    |     |     | ND  |    |    |    |    |    |    |    |
| 8 地下水(ろ過)*   |        | ND |     |     |     |    |    | ND  |     |     |    |     | ND  |     |    |     |       | ND  |    |    |     |     | ND  |    |     |     |     | ND |     |     |     |     | ND |     |     |     |    | ND  |     |     |     |    | ND  |     |     |    |     | ND  |     |    |     |     |     |    |    |    |    |    |    |    |

- (注) 1) 単位: Bq/L  
 2) ※: 試料を孔径0.45 μmのメンブランフィルターでろ過した後の測定値を示す。  
 3) 地下水は地下水集水管排水を対象とした。  
 4) 【ND】は、Cs-134,Cs-137ともに検出下限値(1Bq/L)未満であることを示す。

浸出水原水、処理水、放流水及び地下水の放射能濃度 (Cs-134,Cs-137) (令和2年度)

| 実施年度                     | 令和2年度 |    |    |     |     |     |    |     |     |     |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |    |     |     |     |     |     |     |     |     |    |     |     |     |     |    |     |     |     |    |     |     |     |    |     |     |     |    |    |    |    |
|--------------------------|-------|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|-----|-----|-----|-----|-----|----|-----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|----|----|
|                          | 4月    |    |    |     | 5月  |     |    |     | 6月  |     |    |     | 7月  |     |    |    | 8月  |     |     |    | 9月  |     |     |    | 10月 |     |     |    | 11月 |     |     |     | 12月 |     |     |     | 1月 |     |     |     | 2月  |    |     |     | 3月  |    |     |     |     |    |     |     |     |    |    |    |    |
|                          | 調査日   | 2日 | 9日 | 16日 | 23日 | 28日 | 7日 | 14日 | 21日 | 28日 | 4日 | 11日 | 18日 | 25日 | 2日 | 9日 | 16日 | 22日 | 30日 | 6日 | 13日 | 20日 | 27日 | 3日 | 10日 | 17日 | 25日 | 1日 | 8日  | 15日 | 22日 | 29日 | 5日  | 12日 | 19日 | 26日 | 3日 | 10日 | 17日 | 24日 | 28日 | 7日 | 14日 | 21日 | 28日 | 4日 | 10日 | 18日 | 25日 | 4日 | 11日 | 18日 | 23日 |    |    |    |    |
| 1 浸出水原水(未処理)             | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND | ND |
| 2 浸出水原水(ろ過) <sup>※</sup> | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  |    |    |    |    |
| 3 処理水(未処理)               | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  |    |    |    |    |
| 4 処理水(ろ過) <sup>※</sup>   | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  |    |    |    |    |
| 5 放流水(未処理)               | ND    |    |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |    |     | ND  |     |     |     |     |     |     |    | ND  |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |
| 6 放流水(ろ過) <sup>※</sup>   | ND    |    |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |    |     | ND  |     |     |     |     |     |     |    | ND  |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |
| 7 地下水(未処理)               | ND    |    |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |    |     | ND  |     |     |     |     |     |     |    | ND  |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |
| 8 地下水(ろ過) <sup>※</sup>   | ND    |    |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |    |     | ND  |     |     |     |     |     |     |    | ND  |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |

- (注) 1) 単位: Bq/L  
 2) ※: 試料を孔径0.45 μmのメンブランフィルターでろ過した後の測定値を示す。  
 3) 地下水は地下水集水管排水を対象とした。  
 4) 【ND】は、Cs-134,Cs-137ともに検出下限値(1Bq/L)未満であることを示す。

浸出水原水、処理水、放流水及び地下水の放射能濃度 (Cs-134,Cs-137) (令和3年度)

| 実施年度                     | 令和3年度 |    |    |     |     |     |    |     |     |     |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |     |     |     |     |     |     |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |    |     |     |     |    |    |    |    |
|--------------------------|-------|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|----|----|
|                          | 4月    |    |    |     | 5月  |     |    |     | 6月  |     |    |     | 7月  |     |    |    | 8月  |     |     |    | 9月  |     |     |    | 10月 |     |     |     | 11月 |     |     |     | 12月 |     |     |     | 1月 |    |     |     | 2月  |    |     |     | 3月  |    |     |     |     |    |     |     |     |    |    |    |    |
|                          | 調査日   | 2日 | 8日 | 15日 | 22日 | 28日 | 6日 | 13日 | 20日 | 27日 | 3日 | 10日 | 17日 | 24日 | 1日 | 8日 | 15日 | 21日 | 29日 | 5日 | 10日 | 19日 | 26日 | 2日 | 9日  | 16日 | 22日 | 30日 | 7日  | 14日 | 21日 | 28日 | 4日  | 11日 | 19日 | 25日 | 2日 | 9日 | 16日 | 23日 | 28日 | 6日 | 13日 | 20日 | 27日 | 3日 | 10日 | 17日 | 24日 | 3日 | 10日 | 17日 | 24日 |    |    |    |    |
| 1 浸出水原水(未処理)             | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND | ND |
| 2 浸出水原水(ろ過) <sup>※</sup> | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  |    |    |    |    |
| 3 処理水(未処理)               | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  |    |    |    |    |
| 4 処理水(ろ過) <sup>※</sup>   | ND    | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  |    |    |    |    |
| 5 放流水(未処理)               |       | ND |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |     |     | ND  |     |     |     |     |     |     |    | ND |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |
| 6 放流水(ろ過) <sup>※</sup>   |       | ND |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |     |     | ND  |     |     |     |     |     |     |    | ND |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |
| 7 地下水(未処理)               |       | ND |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |     |     | ND  |     |     |     |     |     |     |    | ND |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |
| 8 地下水(ろ過) <sup>※</sup>   |       | ND |    |     |     |     |    |     | ND  | ND  |    |     |     | ND  |    |    |     |     |     |    |     | ND  |     |    |     |     |     |     |     | ND  |     |     |     |     |     |     |    | ND |     |     |     |    |     |     |     | ND |     |     |     |    |     |     |     |    |    |    |    |

- (注) 1) 単位: Bq/L  
 2) ※: 試料を孔径0.45 μmのメンブランフィルターでろ過した後の測定値を示す。  
 3) 地下水は地下水集水管排水を対象とした。  
 4) 【ND】は、Cs-134,Cs-137ともに検出下限値(1Bq/L)未満であることを示す。

浸出水原水、処理水、放流水及び地下水の放射能濃度 (Cs-134,Cs-137) (令和4年度)

| 実施年度                     | 令和4年度 |    |     |     |     |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |    |    |     |     |     |    |     |     |     |    |     |     |     |    |    |     |     |     |    |     |     |     |    |    |     |     |    |    |     |     |     |    |    |    |
|--------------------------|-------|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|-----|----|----|-----|-----|----|----|-----|-----|-----|----|----|----|
|                          | 4月    |    |     |     | 5月  |    |     |     | 6月  |    |    |     | 7月  |     |    |     | 8月  |     |    |     | 9月  |     |    |    | 10月 |     |     |    | 11月 |     |     |    | 12月 |     |     |    | 1月 |     |     |     | 2月 |     |     |     | 3月 |    |     |     |    |    |     |     |     |    |    |    |
|                          | 調査日   | 8日 | 12日 | 19日 | 27日 | 6日 | 12日 | 18日 | 26日 | 2日 | 9日 | 15日 | 23日 | 30日 | 7日 | 14日 | 21日 | 28日 | 4日 | 10日 | 18日 | 25日 | 1日 | 8日 | 15日 | 22日 | 29日 | 6日 | 13日 | 20日 | 27日 | 2日 | 10日 | 17日 | 24日 | 1日 | 8日 | 15日 | 22日 | 28日 | 5日 | 12日 | 19日 | 26日 | 2日 | 9日 | 16日 | 22日 | 2日 | 9日 | 16日 | 23日 | 30日 |    |    |    |
| 1 浸出水原水(未処理)             | ND    | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND | ND |
| 2 浸出水原水(ろ過) <sup>※</sup> | ND    | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND | ND | ND  | ND  |     |    |    |    |
| 3 処理水(未処理)               | ND    | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND | ND | ND  | ND  |     |    |    |    |
| 4 処理水(ろ過) <sup>※</sup>   | ND    | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND  | ND | ND  | ND  | ND  | ND | ND | ND  | ND  | ND | ND | ND  | ND  |     |    |    |    |
| 5 放流水(未処理)               |       | ND |     |     |     |    |     | ND  |     |    |    |     | ND  |     |    |     |     |     |    |     | ND  |     |    |    |     |     |     |    | ND  |     |     |    |     |     |     |    | ND |     |     |     |    |     |     |     | ND |    |     |     |    |    |     |     |     |    |    |    |
| 6 放流水(ろ過) <sup>※</sup>   |       | ND |     |     |     |    |     | ND  |     |    |    |     | ND  |     |    |     |     |     |    |     | ND  |     |    |    |     |     |     |    | ND  |     |     |    |     |     |     |    | ND |     |     |     |    |     |     |     | ND |    |     |     |    |    |     |     |     |    |    |    |
| 7 地下水(未処理)               |       | ND |     |     |     |    |     | ND  |     |    |    |     | ND  |     |    |     |     |     |    |     | ND  |     |    |    |     |     |     |    | ND  |     |     |    |     |     |     |    | ND |     |     |     |    |     |     |     | ND |    |     |     |    |    |     |     |     |    |    |    |
| 8 地下水(ろ過) <sup>※</sup>   |       | ND |     |     |     |    |     | ND  |     |    |    |     | ND  |     |    |     |     |     |    |     | ND  |     |    |    |     |     |     |    | ND  |     |     |    |     |     |     |    | ND |     |     |     |    |     |     |     | ND |    |     |     |    |    |     |     |     |    |    |    |

- (注) 1) 単位: Bq/L  
 2) ※: 試料を孔径0.45 μmのメンブランフィルターでろ過した後の測定値を示す。  
 3) 地下水は地下水集水管排水を対象とした。  
 4) 【ND】は、Cs-134,Cs-137ともに検出下限値(1Bq/L)未満であることを示す。



